

VALLEY VIEW MUTUAL WATER COMPANY
YEAR 2025
CONSUMER CONFIDENCE REPORT

INTRODUCTION

Valley View Mutual Water Company is committed to keeping you informed about the quality of your drinking water. This report is provided to you annually. It includes information describing where your drinking water comes from, the constituents found in your drinking water and how the water quality compares with the regulatory standards. We are proud to report that during year 2025, the drinking water provided by Valley View Mutual Water Company met or surpassed all Federal and State drinking water standards. We remain dedicated to providing you with a reliable supply of high quality drinking water.

For information regarding opportunities to participate in decisions that may affect the quality of your water, please contact Ms. Patty Vega at (626) 960-2759.

WHERE DOES MY DRINKING WATER COME FROM?

Valley View Mutual Water Company's water supply comes from one production well in the Main San Gabriel Groundwater Basin, and purchased water from Valley County Water District. Valley County Water District's water supply comes from production wells in the Main San Gabriel Groundwater Basin. The water is disinfected with chlorine before it is delivered to your home.



WHAT ARE WATER QUALITY STANDARDS?

In order to ensure that tap water is safe to drink, the United States Environmental Protection Agency (USEPA) and the State Water Resources Control Board, Division of Drinking Water (DDW) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration regulations and California law also establish limits for contaminants in bottled water that provide the same protection for public health.

Drinking water standards established by USEPA and DDW set limits for substances that may affect consumer health or aesthetic qualities of drinking water. The chart in this report shows the following types of water quality standards:

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Secondary MCLs** are set to protect the odor, taste, and appearance of drinking water.
- **Primary Drinking Water Standard:** MCLs for contaminants that affect health along with their monitoring

and reporting requirements and water treatment requirements.

- **Regulatory Action Level (AL):** The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements that a water system must follow.

WHAT IS A WATER QUALITY GOAL?

In addition to mandatory water quality standards, USEPA and DDW have set voluntary water quality goals for some contaminants. Water quality goals are often set at such low levels that they are not achievable in practice and are not directly measurable. Nevertheless, these goals provide useful guideposts and direction for water management practices. The chart in this report includes three types of water quality goals:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by USEPA.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

WHAT CONTAMINANTS MAY BE PRESENT IN SOURCES OF DRINKING WATER?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.



Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides** that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals that are byproducts of industrial processes and petroleum production, and can also come

from gasoline stations, urban stormwater runoff, agricultural application and septic systems.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

ARE THERE ANY PRECAUTIONS THE PUBLIC SHOULD CONSIDER?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

WHAT IS IN MY DRINKING WATER?

Your drinking water is regularly tested using DDW-approved methods to ensure its safety. The table in this report lists all the constituents **detected** in your drinking water that have Federal and State drinking water standards. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old. Detected unregulated constituents and other constituents of interest are also included.

LEAD IN TAP WATER

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Valley View Mutual Water Company is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Valley View Mutual Water Company at (626) 960-2759. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Valley View Mutual Water Company completed its lead service line inventory in 2024. You can request for a hard-copy of the Valley View Mutual Water Company's lead service line inventory in our office. For more information, please contact Valley View Mutual Water Company at (626) 960-2759.

DRINKING WATER SOURCE ASSESSMENT

In accordance with the federal Safe Drinking Water Act, an assessment of the drinking water sources for Valley View Mutual Water Company was completed in December 2002. The purpose of the drinking water source assessment is to promote source water protection by identifying types of activities in the proximity of the drinking water sources which could pose a threat to the water quality. The assessment concluded that Valley View Mutual Water Company's wells are not vulnerable to any activity associated with contaminants detected in the water supply. However, the sources are considered vulnerable to the high density of housing. A copy of the complete assessment is available at Valley View Mutual Water Company at 13730 East Los Angeles Street, Baldwin Park, California 91706. You may request a summary of the assessment to be sent to you by contacting Ms. Patty Vega at 626-960-2759.

An assessment of the drinking water sources for Valley County Water District was completed in December 2002. The assessment concluded that Valley County Water District's sources are considered most vulnerable to the following activities or facilities associated with contaminants detected in the water supply: gasoline stations, chemical/petroleum processing and storage, automobile repair shops, fleet/truck/bus terminals, food processing, landfills/dumps, leaking underground storage tanks, dry cleaners and metal plating/finishing/fabricating. In addition, the sources are considered most vulnerable to the following activities or facilities not associated with contaminants detected in the water supply: pesticide/fertilizer/petroleum storage and transfer areas, railroad yards/maintenance/fueling area. A copy of the complete assessment is available at Valley View Mutual Water Company at 13730 East Los Angeles Street, Baldwin Park, California 91706. You may request a summary of the assessment to be sent to you by contacting Ms. Patty Vega at 626-960-2759.

QUESTIONS?

For more information or questions regarding this report, please contact Ms. Patty Vega at (626) 960-2759.

Este informe contiene información muy importante sobre su agua potable. Para mas información ó traducción , favor de contactar a Ms. Patty Vega. Telefono: (626) 960-2759.

此份有關你的食水報告,內有重要資料和訊息,請找他人為你翻譯及解釋清楚。

VALLEY VIEW MUTUAL WATER COMPANY 2025 WATER QUALITY TABLE

CONSTITUENT AND (UNITS)	MCL or [MRDL]	PHG or (MCLG) or [MRDLG]	DLR	GROUNDWATER SOURCES		YEAR LAST TESTED	TYPICAL ORIGINS
				Average Results (a)	Range (a) Minimum-Maximum		
Primary Drinking Water Standards -- Health Related Standards							
DISINFECTION							
Total Trihalomethanes (TTHM) (µg/l) (b)	80	NA	1	6.3	0.7 - 6.3	Tested Annually	By-product of drinking water chlorination
Haloacetic Acids (five) (HAA5) (µg/l) (b)	60	NA	1-2	ND	ND	Tested Annually	By-product of drinking water chlorination
Chlorine Residual (mg/l) (b)	[4]	[4]	NA	0.59	0.3 - 0.9	Tested Weekly	Drinking water disinfectant
MICROBIOLOGICAL							
E. coli	(c)	(0)	--	0 (Highest Number of Detections)	0 (No. of Months in Violation)	Tested Weekly	Human and animal fecal waste
INORGANIC CHEMICALS							
Barium (mg/l)	1	2	0.1	0.14	0.14	2025	Erosion of natural deposits
Copper (mg/l) (d)	AL = 1.3	0.3	0.05	0.11	ND - 0.33	2025	Corrosion of household plumbing system
Fluoride (mg/l)	2	1	0.1	0.26	0.25 - 0.26	2025	Erosion of natural deposits
Hexavalent Chromium (µg/l)	10	0.02	0.1	0.67	0.67	2025	Erosion of natural deposits; Industrial waste discharge
Lead (µg/l) (d)	AL = 15	0.2	5	ND	ND - 11	2025	Corrosion of household plumbing system
Nitrate as N (mg/l)	10	10	0.4	0.99	0.98 - 1	2025	Leaching from fertilizer use; septic tanks
RADIOACTIVITY							
Uranium (pCi/l)	20	0.43	1	2.3	2.3	2024	Erosion of natural deposits
Secondary Drinking Water Standards -- Aesthetic Standards, Not Health-Related							
Chloride (mg/l)	500	NA	NA	11	11	2025	Erosion of natural deposits
Foaming Agents (MBAS) (µg/l)	500	NA	NA	150	150	2025	Municipal and industrial waste discharges
Odor (Units)	3	NA	NA	1	1	2025	Naturally occurring organic materials
Specific Conductance (µmho/cm)	1600	NA	NA	460	460	2025	Substances that form ions in water
Sulfate (mg/l)	500	NA	NA	18	18	2025	Erosion of natural deposits
Total Dissolved Solids (mg/l)	1000	NA	NA	250	250	2025	Erosion of natural deposits
Other Constituents of Interest							
Hardness as CaCO3 (mg/l)	NA	NA	NA	220	220	2025	Erosion of natural deposits
Hardness as grains per gallon	NA	NA	NA	13	13	2025	Erosion of natural deposits
Sodium (mg/l)	NA	NA	NA	14	14	2025	Erosion of natural deposits
NOTES							
µg/l = parts per billion or micrograms per liter	AL = Action Level		MRDLG = Maximum Residual Disinfectant Level Goal				
mg/l = parts per million or milligrams per liter	DLR = Detection Limit for Purposes of Reporting		NA = Not Applicable				
µmho/cm = micromhos per centimeter	MCL = Maximum Contaminant Level		ND = Not Detected at DLR				
pCi/l = picoCurie per liter	MCLG = Maximum Contaminant Level Goal		PHG = Public Health Goal				
MBAS = methylene blue active substances	MRDL = Maximum Residual Disinfectant Level						
(a) The results reported in the table are average and range of concentrations of the constituents detected in Valley View Mutual Water Company wells during 2025 or from the most recent tests, except for total trihalomethanes, haloacetic acids, chlorine residual, and lead and copper which are described below.							
(b) Samples were collected in the distribution system. For chlorine residual, the highest running annual average and the range of the individual results are presented.							
(c) Routine and repeat samples are total coliform-positive and either is E. coli-positive or system fails to take repeat samples following E. coli-positive routine sample or system fails to analyze total coliform-positive repeat sample for E. coli.							
(d) Concentrations were measured at the tap. The 90th percentile concentration is reported in the table. Out of 22 distribution system locations sampled, none of the results for copper or lead exceeded the Action Level. The samples were collected in June 2025. The regulatory Action Level is the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.							

2025 VALLEY COUNTY WATER DISTRICT WATER QUALITY TABLE

CONSTITUENT AND (UNITS)	MCL	PHG	DLR	GROUNDWATER SOURCES		YEAR LAST TESTED	TYPICAL ORIGINS
				Average Results (a)	Range (a) Minimum-Maximum		
Primary Drinking Water Standards -- Health Related Standards							
INORGANIC CHEMICALS							
Arsenic (µg/l)	10	0.004	2	ND	ND - 2.2	2025	Erosion of natural deposits
Barium (mg/l)	1	2	0.1	ND	ND - 0.13	2025	Erosion of natural deposits
Fluoride (mg/l)	2	1	0.1	0.26	0.21 - 0.29	2025	Erosion of natural deposits
Hexavalent Chromium (µg/l)	10	0.02	0.1	0.37	0.33 - 0.39	2024	Erosion of natural deposits
Nitrate as N (mg/l)	10	10	0.4	1.3	0.83 - 4.2	2025	Leaching from fertilizer use; septic tanks
RADIOACTIVITY							
Uranium (pCi/l)	20	0.43	1	ND	ND - 1.3	2023	Erosion of natural deposits
Secondary Drinking Water Standards -- Aesthetic Standards, Not Health-Related							
Chloride (mg/l)	500	NA	NA	13	9.7 - 16	2024	Erosion of natural deposits
Specific Conductance (µmho/cm)	1,600	NA	NA	340	320 - 360	2024	Substances that form ions in water
Sulfate (mg/l)	500	NA	NA	19	17 - 20	2024	Erosion of natural deposits
Total Dissolved Solids (mg/l)	1,000	NA	NA	240	230 - 250	2025	Erosion of natural deposits
Turbidity (NTU)	5	NA	NA	0.24	0.1 - 0.55	2024	Soil runoff
Other Constituents of Interest							
Hardness as CaCO3 (mg/l)	NA	NA	NA	140	130 - 150	2024	Erosion of natural deposits
Hardness as grains per gallon	NA	NA	NA	8.2	7.6 - 8.8	2024	Erosion of natural deposits
Sodium (mg/l)	NA	NA	NA	14	13 - 15	2024	Erosion of natural deposits
NOTES							
µg/l = parts per billion or micrograms per liter		NTU = Nephelometric Turbidity Units				NA = Not Applicable	
mg/l = parts per million or milligrams per liter		DLR = Detection Limit for Purposes of Reporting				ND = Not Detected at DLR	
µmho/cm = micromhos per centimeter		MCL = Maximum Contaminant Level				PHG = Public Health Goal	
pCi/l = picoCurie per liter							
(a) The results reported in the table are average and range of concentrations of the constituents detected in Valley County Water District source water during 2025 or from the most recent test.							